



CT 3032/2014

8 April 2014

To all Prospective Bidders:

WORKS TENDER FOR THE SUPPLY, INSTALLATION AND COMMISSIONING OF MECHANICAL AND ELECTRICAL SERVICES FOR THE NEW SIXTH FORM BLOCK AT VICTORIA (RABAT) GOZO IN AN ENVIRONMENTALLY FRIENDLY MANNER

Clarification Number 1

Reference is made to the above-mentioned tender.

Enclosed herewith please find a clarification, which is construed to form an integral part of the Tender Document.

Question 1:

I would like to verify the specification of the CCTV system cameras. The tenders' CCTV specification document specifies the following 3 different types of cameras:

- the 1M pixel camera,
- the 3M pixel camera and,
- the 3M pixel camera c/w wide dynamic range.

The BOQ lists the CCTV system as Lump Sum. Therefore all camera units should be quantified according to the ELV drawings, but the ELV drawing does not indicate the type of camera.

Reply 1:

The contractors shall quote for 3Mpixel Cameras for both internal and external areas for the quantities indicated in the Bills of Quantities.

All other tender documents, conditions and requirements, which are not superseded by this Clarification, remain in place.

Anthony Cachia
Director General (Contracts)