



CT 2035/2014

27 March 2014

To all Prospective Bidders:

**CT2035/2014 – WORKS TENDER FOR THE SUPPLY, INSTALLATION AND COMMISSIONING OF MECHANICAL & ELECTRICAL SERVICES AT THE NEW CLASSROOMS AT VINCENZO BORG BRARED SCHOOL, BIRKIRKARA IN AN ENVIRONMENTALLY FRIENDLY MANNER**

**Clarification Number 3**

Reference is made to the above-mentioned tender, for which the closing date is on the 10<sup>th</sup> April 2014 at 10.00am (Malta time).

Enclosed herewith please find a clarification that is to be considered as part of the tender document.

---

*Question 1: In point 3.5.4.02 it is stated that they want a fully IP distributed architecture, then in point 3.5.4.03 Telephone sets - Telephone sets shall be analogue, Points are contradicting.*

*Answer 1: The PABX shall be digital type.*

*Question 2: In item 3.3.12 its states "IT Wall Mounted cabinet 42U according to specifications for IT & Telephone network only." The cabinet is too big to be wall mounted - please confirm.*

*Answer 2: The cabinet shall be floor standing.*

All other tender documents, conditions and requirements, which are not superseded by this Clarification, remain in place.

**Lorraine Mangion Duca**  
f/Director General (Contracts)